

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 if the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
Schneider Electric 1354 Clifford Ave. Loves Park, IL 61111 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 4 (135-2004)	May 2013

Product Name	Model Number	Software Version
I/A Series [®] MicroNet [™] Unitary Controller	MNB-300	1.43
I/A Series [®] MicroNet™ VAV Controller	MNB-V2	1.43
I/A Series [®] MicroNet™ VAV Controller	MNB-V1	1.43
I/A Series [®] MicroNet™ Zone Controller	MNB-70	1.43

Device Profiles

Pro file	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-State Output	Multi-State Value	Device

Data Link Layer Options

Media	Options
MS/TP master	9600, 19.2k, 38.4k, 76.8k
MS/TP slave	9600, 19.2k, 38.4k, 76.8k

Character Set Support

ANSI X3.4